

BUILDING SAFETY CERTIFICATE

No:

Dated:20-02-2025


Certified that the existing building Shree Renuka Sugar Development Foundation's SMT.SHANTABAI DESHPANDE PUBLIC SCHOOL KOKATNURU-591230 (name of the building or premise) at Kokatnuru village in Athani Taluk of Belagavi District (address) comprised of Ground Floor basement(s) and First Floor (upper floors) owned/occupied by Shree Renuka Sugar Development Foundation's SMT.SHANTABAI DESHPANDE PUBLIC SCHOOL KOKATNURU (name of the institution) have complied with the Building Safety requirements in accordance with National Building Code Rules, and verified by the officers concerned of Government of Karnataka Public Works Department (Name of the Department/Govt.) on 01/02/2025 (date of inspection) in presence of The Principal and Admin of SMT.SHANTABAI DESHPANDE PUBLIC SCHOOL KOKATNURU (name and address of the Principal and administrator) and that the building/premise is fit for the Occupancy On the basis of Structural Stability Test conducted by the faculty of S.J.P.N TRUST'S POLYTECHNIC NIDASOSHI-591236 by using Rebound Hammer Instrument (NON DESTRUCTIVE TEST), from Nursery classes up to Xth standard Classes with the effect from 20/02/2025 for a period of ONE YEAR in accordance with rule and subject to compliance of the specific conditions as appended.

- 1) During the period of One Year if building showas any cracks, leakages from ceiling, Spalling or any Differential Settlement Report to your Competent Authorities Immediately.
- 2) By the inspection time our concerned section officer has observed presence of Hair line Cracks which are clearly visible. Hence it is suggested take Precautionary measures as soon as possible.
- 3) You must maintain documents pertaining to School Building such as Approved Structural Drawings, Designs and Detailing, Plan , Elevation, Lay out plan, Key map , Quality Test Report of Drinking water etc.
- 4) Have a Paved Roads around School Building Premise for the Movement of Fire Engine.
- 5) Periodic Maintainance of School Building is Mandatory.

Issued on 20-02-2025 At Athani by.


MANAGER
Smt .Shantabai Deshpande Public School
Affiliated to CBSE Board No 830433
Kokatnur 591230
Athani Dist : Belagavi

Signature with Seal :


Assistant Executive Engineer
P.W.D. Sub Div. Athani.

Name: J.A.Hiremath.

Designation: Assistant Executive Engineer.

PRINCIPAL

Name and Address of Department/Office: PWD sub-division Athani
Smt. Shantabai Deshpande Public School
Affiliated CBSE Board No: 830433
Kokatnur-591230
Tal: Athani
Dist: Belagavi